



OEA

140.6

147

110

DATE : February 11, 1980  
TO : Peter Willing  
FROM : Bill Riley  
SUBJECT: Specific Recommendations for 1981 CIP's

PCB & Oil Spill containment

1. Containment structures beneath transformer decks and PCB capacitor banks at Gorge, Diablo and Ross, with installation of catchment basins and oil detection alarms.
2. Containment structures beneath transformers and PCB capacitor banks at Duwamish Substation.
3. At SSC, another PCB storage shed with impermeable floor, curb and roof for the waste transformer oil storage tank. This shed should have ample space for enough 55 gallon barrels to store 3-4 months worth of waste T-oil (see 44 CFR 761.42 attached.)
4. Dissolved gas/PCB analysis laboratory

Recreational Facilities at Boundary

Without some idea of existing facilities, use and demand, I can't really justify my gut feeling that something is needed.

WR:rm

Attachment

cc: Henault  
Riley  
OEA (3)  
File